

DOCUMENT 00910

**ADDENDA**

**EL DORADO IRRIGATION DISTRICT  
El Dorado Hills Water Treatment Plant Expansion To 26 MGD Project**

**ADDENDUM NO. 4  
June 23, 2009**

This Addendum No. 4 ("Addendum") is dated and the date set forth above modifies certain Bidding Documents issued by the El Dorado Irrigation District ("District") in connection with the District's El Dorado Hills Water Treatment Plant Expansion to 26 MGD Project. All capitalized terms not otherwise defined herein shall have the meanings provided in the Bidding Documents. There are no other amendments to the Bidding Documents other than expressly contained in this Addendum.

## El Dorado Irrigation District

### EDHWTP Expansion To 26 MGD Project

#### ADDENDUM NO. 4

June 23, 2009

#### Questions & Answers

Item No.	Spec. Section	Description
Q4-1	02512	<p><b>Question:</b> "Can you please clarify what the spec is for the hot asphalt mix? Do you require Marshall Mix and if yes, what is the blow on the mix? "</p> <p><b>Answer:</b> 1/2" max, medium gradation, Type B. See change this Addendum.</p>
Q4-2	MY101	<p><b>Question:</b> "We have a question in regards to page 38 on the plans. The plans show Modification to Filters 1 and 2. However the detail (A Steel Pipe Concrete Wall Fitting) on the right side of the page refers to filter F03 and F04. Are we to install/replace valves on Filters 03 and 04 as well as on filters 1 and 2?"</p> <p><b>Answer:</b> Detail A, callout "BFV (F-03 and F-04)" is not correct. Intent is four (4) butterfly valves indicated in bold on the sheet are to be replaced. See change this Addendum.</p>

#### Specifications


Item No.	Spec. Section	Description
S4-1	00100	BID SUBMISSION. <b>DELETE</b> "June 25 <sup>th</sup> " and <b>REPLACE</b> with "June 29 <sup>th</sup> by 3:00 p.m."
S4-2	00200 & Addendum No. 2	RECEIPT OF BIDS. <b>DELETE</b> "June 25" and <b>REPLACE</b> with "June 29, by 3:00 p.m."  Paragraph 1, second paragraph, third sentence. <b>REVISE</b> "Envelope "B" shall be due the following day, June 26, by 2:00 p.m" to "Envelope "B" shall be due the following day, June 30, by 2:00 p.m."
S4-3	02512	Paragraph 2-2. <b>ADD</b> the following sentence at the beginning of the first paragraph: "All asphalt concrete shall be 1/2" max, medium gradation, Type B".


Item No.	Spec. Section	Description
S4-4	00700	<p>Paragraph 9.A.2 of Document 00700 is hereby changed to read:</p> <p>"2. Pass-through of Warranties and Guarantees: Contractor shall pass-through and assign to District any and all warranties and guarantees from any supplier or manufacturer of any equipment or materials used in the Project and shall supply District with all documentation of any such warranty or guaranty. Contractor shall not be obligated to perform any such warranties or guarantees provided by any supplier or manufacturer of any equipment or materials used in the Project."</p>

### Drawings

Item No.	Drawing No.	Sheet No.	Description
D4-1	MY101	38	For DETAIL A. <b>DELETE</b> callout "BFV (F-03 and F-04)" and <b>REPLACE</b> with "BFV (TAG ID VARIES)".

**THIS ADDENDUM AND ALL OTHERS ISSUED SHALL BE PART OF THE RFP.**

  
Cindy Megerdigian, P.E.  
Hydro/Water Engineering Manager

  
Date

**END OF ADDENDUM NO. 4**

**Acknowledgement of receipt of Addendum No. 4 for the El Dorado Hills Water Treatment Plant Expansion to 26 MGD, Project No. 05002E.03, Contract No. E09-02.**

Please sign and return by FAX a copy of this page to the Records Management and Administrative Services Division, El Dorado Irrigation District, at (530) 622-8597 to acknowledge receipt of Addendum No. 4 for this Project consisting of 4 pages.

\_\_\_\_\_  
Signature and Print Name

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company

END OF DOCUMENT